



CSA
Group

Letter of Attestation

Document: 70134227

Master Contract: 259077

Project: 70134227

Date Issued: May 10, 2017

Issued to: Altenergy Power System, Inc.
No. 1 Yatai Road
Jiaxing 314050
China
Attention: Mr. Jiang Guofeng

*CSA Group hereby confirms that it has completed an evaluation of
Utility Interactive Photovoltaic Inverters,*

*Models YC500A, YC500I, YC500-K,
YC1000-3-480, YC1000-3-K480 and YC1000-3-208*

*CSA Group hereby attests that the products identified above and described in CSA test report
70134227 complies with the following requirements/tests, to the extent applicable:*

NFPA 70 (National Electrical Code) 2014, Article 690.12
Rapid Shutdown of PV Systems on Buildings

And

NFPA 70 (National Electrical Code) 2017, Article 690.12
Rapid Shutdown of PV Systems on Buildings

Notes:

1. Units verified against CSA test report 70134227, dated May 10, 2017.

Issued by:

Kyle Song

Issued by Kyle Song, Certifier

THIS LETTER OF ATTESTATION DOES NOT AUTHORIZE THE USE OF THE CSA MARK ON THE SUBJECT PRODUCTS. QUOTATIONS FROM THE TEST REPORT OR THE USE OF THE NAME OF THE CANADIAN STANDARDS ASSOCIATION AND CSA INTERNATIONAL OR ITS REGISTERED TRADEMARK, IN ANY WAY, IS NOT PERMITTED WITHOUT PRIOR WRITTEN CONSENT OF THE CANADIAN STANDARDS ASSOCIATION OR CSA GROUP