



BV LCIE
CHINA
Number

N°1766AS05ZEM24538

ATTESTATION of conformity with European Directives

Product: **Grid-tied Microinverter**
Reference: **YC600**
Issued to: **ALTENERGY POWER SYSTEM INC.**
Address: **No.1 Yatai Road, Jiaxing 314050 Zhejiang Province,P.R. China**
Manufacturer: **ALTENERGY POWER SYSTEM INC.**
Technical characteristics: **See Next Page**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 62109-1: 2010 EN 62109-2: 2011	ZEM-16OC1802FTSP-1_CE ZEM-16OC1802FTSP-2_CE	26/05/2017

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China),), May 26th, 2017.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE
CHINA
Number

N°1766AS05ZEM24538

Ratings.....:	YC600
MPP DC voltage range [V].....:	22-45V dc
Max. Input DC voltage [V].....:	55V dc
Input DC current [A].....:	Max. 2*12A
Output AC voltage [V].....:	230/240 Vac, 50Hz
Output AC current [A].....:	2,39A
Output power [VA].....:	Max. continuous:550,Peak:600

Shanghai (P.R. China),), May 26th, 2017.



Dio Zhang
Operation Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email:contact@cn.bureauveritas.com

Version 3/2016.02.19