



# Certificate of Compliance

**Certificate:** 70184750

**Master Contract:** 259077

**Project:** 70184750

**Date Issued:** 2018-05-17

**Issued to:** Altenergy Power System Inc.  
No.1 Yatai Road,  
Jiaxing, Zhejiang, 314050  
CHINA  
Attention: Guofeng Jiang

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *Michael Tong*  
Michael Tong

## **PRODUCTS**

CLASS - C531109 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Utility Interactive Microinverter, Model QS1200 and QS1, Rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 107.1-16 - General Use Power Supplies

\*UL Std. No. 1741 - Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (February 15, 2018)

\*Note: Conformity to UL 1741-Second Edition (February 15, 2018) includes compliance with applicable requirements of IEEE 1547 (R2008) and IEEE 1547.1 (R2011).