



Certificate of Compliance

Certificate: 70154937

Master Contract: 259077

Project: 70212786

Date Issued: 2019-01-25

Issued to: Altenergy Power System Inc.
No.1 Yatai Road
Jiaxing, Zhejiang 314050
CHINA
Attention: Kevin Lu

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Allen Yao
Allen Yao

PRODUCTS

CLASS - C531109 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation Power Systems Equipment - Certified to U.S. Standards

Grid Support Utility Interactive Microinverter, Model YC600, Rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 107.1-16 - General Use Power Supplies

*UL 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision February 15, 2018)

*Note: Conformity to UL 1741 (Second Edition, Revision February 15, 2018) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547.1-2005(R2011), California Rule 21 and Supplement SA.