

# ECU-C Energy Communication Unit with advanced functions Quick Installation Guide

This guide is for reference only and assumes you have access to, and have read the detailed instructions in the ECU-C Users Manual (available at [APsystems.com](http://APsystems.com)).

## Step 1: Power-on ECU

ECU-C installed in the YC1000 system, connect the supplied power cable to the AC input port. can also be used 16V DC power supply, the 16V DC power line access to DC on the ECU-C interface. **If only single-phase power is needed, the L1 must be connected.**

	L1	L2	L3	N	PE
Three Phase	√	√	√	√	√
Single Phase	√	×	×	√	√

**NOTE: Do not put the antennas inside a metal box, that will block the signal.**

## Step 2: Connect ECU to Internet

Option 1: LAN connection – use the LAN Cable to connect ECU to a Broadband Router.

Option 2: WiFi connection.

Turn on the Wi-Fi function on PC or phone. Scan the ECU’ s SSID which named “ECU-WIFI\_XXXX” (the “xxxx” refers to the last 4 numbers of the ECU-C ID), connect to the ECU-C’ s SSID. The first connection has no password. Using a standard web browser on your computer, Enter the ECU’ s IP 172.30.1.1 into browser to access the local web. Select “Administration” and “WLAN” , then click “WLAN” tab.


Select the button next to the available network that you wish to access SSID, and a password entry field will be displayed below the network name.

Enter the password into the password entry field, then click “Connect” . If ECU has connected to the router, it will display the SSID and IP address.

## Step 3: Connect microinverters to ECU.

- 1) Scan the ECU’ s SSID on PC and phone, and connect to ECU. Enter the ECU’ s IP 172.30.1.1 into browser to access the local web. This should bring up the screen below:

[English](#) | [Chinese](#)





Home	
ECU ID	203100026410
Lifetime generation	70.26 kWh
Last System Power	193 W
Generation of Current Day	0.88 kWh
Last Connection to website	2015-09-07 12:45:00
Number of Inverters	1
Last Number of Inverters Online	1
Current Software Version	V4.0
Current Time Zone	Asia/Shanghai
ECU Eth0 Mac Address	80:97:1B:00:67:93
ECU Wlan0 Mac Address	60:C5:A8:E0:99:4B
Inverter Comm. Signal Level	4


2015-09-09 14:11:24  
Wednesday

ENVIRONMENTAL BENEFITS


CO<sub>2</sub> Offset Equivalent to

  
5  
GALLONS

  
2  
TREES

  
51  
KG


2) Click “Administration”, then click “ID management”, and enter the inverter IDs into the ID Management box, or use the Scanning Gun to scan the inverter IDs and copy into the ID Management box. Or using the EMA App, scan the inverter IDs by mobile phone.



3) Click “Update”, and the ID will be updated in the ECU.

#### Step 4: Check power of the microinverters

1) Click “Real Time Data” from the ECU Home, to view the real-time data of all microinverters.




2) If a microinverter does not show up, please confirm if the inverter's ID is correctly input.

#### Step 5: Configure time-zone

- Click “Administration”, then “Date, Time, Time-zone”.

#### Step 6: Select grid profile

- Click “Grid Profile”, then select “Grid profile”.



**NOTE: If you select the wrong grid profile, the inverters will not work normally.**